



THE
**Water
Research**
FOUNDATION

Webcast

Characterizing and Controlling Organics in Direct Potable Reuse Projects

November 19, 2019




JACOBS®



Housekeeping Items


- Submit questions through the question box at any time! We will do a Q&A near the end of the webcast.
- Slides and a recording of the webcast will be available at www.waterrf.org.
- Send an email to Michelle Suazo at msuazo@waterrf.org for a PDH certificate.
- Survey at the end of the webcast.

Input your webinar questions here



Q&A at end of webinar

Download presentation



Slides and recording will be available to WRF subscribers **WITHIN 24 hours** after the webcast

Webcast Agenda

- Background and Participating Utilities
- Summary of Analytical Testing
- Framework Description and TOC Monitoring
- DBPs and Toxicity Index
- CECs and Bioassays
- Testing the Framework
- Summary
- Q&A


Wide Variety of How Organics are Regulated for Potable Reuse

- TOC + MCLs (e.g., SOCs, VOCs, THMs, HAAs)

Location	Organics Limit
California ¹	TOC < 0.5 mg/L
HRSD SWIFT Project	TOC < 4 mg/L
Virginia (Occoquan and Dulles Policies)	COD < 10 mg/L
Georgia (Gwinnett County)	COD < 18 mg/L
Texas (El Paso; Big Spring)	None
Florida	TOC < 3 mg/L; TOX ≤ 0.2 mg/L
EPA Guidelines (2012)	TOC < 2 mg/L; TOX ≤ 0.2 mg/L
<i>De Facto</i> Reuse ²	None
1. Requirements are for 100% groundwater injection 2. Regulated by CWA and SDWA	

Organics Dilemma for Potable Reuse

- Bulk organic measurements (e.g., TOC, COD) may be too broad to accurately reflect exposure to the small fraction of organics that may be harmful or toxic
- Therefore, use of bulk organic limits (e.g., TOC < 2 mg/L) may not be protective of public health and not universally applicable




Research Goals

- Develop a site-specific framework for utilities pursuing direct potable reuse to demonstrate that their DPR water is “safe” from an organics perspective
 - Compare “safety” of potable reuse water to “safety” of local potable water from which DPR water was sourced
 - Compare organics profile at various locations in the domestic water cycle







Utility Selection

- Six potable reuse utilities selected (5 IPR facilities and 1 DPR facility)
- Geographically diverse: four in U.S., two international
- Focused on utilities not using reverse osmosis (RO) based treatment:
 - TOC limit not really necessary for RO (TOC <0.1 mg/L)
 - Implementation is prohibitively expensive at in-land locations




Schimmoller and Kealey, 2014

Participating Utilities – Potable Reuse Schemes




Analytical Testing

- Four samples collected over 1-year at multiple points within the domestic water cycle
 - Bulk organics (**TOC**, COD, UVA)
 - EEM
 - **DBPs (regulated and non-regulated)**
 - **CECs (or TOrCs)**
 - SEC-OCD
 - **Bioassays**
 - Other (e.g., non-targeted analysis)




Sampling in the Domestic Water Cycle

Proposed Framework for Controlling Organics in DPR Projects





Setting Action and Alert Limits for TOC

- Ideally, prevent the potential for elevated hazardous organic chemicals to occur in DPR water
- Selection of limits that are too low can result in unreasonable construction and operating costs
- Numerous drinking water systems provide safe drinking water to their customers at TOC concentrations ranging from below 1 mg/L to above 4 mg/L




TOC in U.S. Potable Water (n=276); AWWA 2017

TOC Provides Some Correlation to Potential Health Relevance




Comparison to TOC in Local Drinking Water

- When DOC in DPR water exceeds DOC in local drinking water, concentration of chemicals increase
- DPR treatment goal: return water's bulk organic characteristics back to approximately that of the local drinking water




Drinking Water TOC in this Study




- TOC ranged from 1- 4 mg/L

What are appropriate TOC Limits for DPR Water?

- **Alert Limit**: 50th percentile of drinking water TOC
 - When DPR water's 30-day running average for TOC exceeds Alert Limit, more analysis required (CECs, DBPs, Bioassays, MCLs)
- **Action Limit**: 1.5 x 95th percentile of drinking water TOC
 - When DPR water's on-line TOC exceeds Action Limit, stop operations



Quarterly Monitoring



Benefits of Including DBPs in Framework

- Margins of safety in potable reuse are lowest for DBPs




TABLE 7-1 Summary of Margin of Safety (MOS) Estimates for the Three Scenarios Analyzed by the Committee

Chemical	Risk-Based Action Level*	MOS Scenario 1, de Facto Reuse	MOS Scenario 2, SAT, No Disinfection	MOS Scenario 3 MF/RO/UV
Nitrosamines				
NDMA	0.7 ng/L	>0.4	>0.4	>0.4
Disinfection byproducts				
Bromate	10 µg/L	N/A	N/A	> 2
Bromoform	80 µg/L	27	160	>160
Chloroform	80 µg/L	16	80	16
DBCA	60 µg/L	>60	>60	>60
DBAN	70 µg/L	>54	>140	N/A
DBCM	80 µg/L	>80	N/A	>160
DCAA	60 µg/L	12	>60	>60
DCAN	20 µg/L	>20	>20	N/A
HAA5	60 µg/L	6	12	12
THM	80 µg/L	2.7	16	8
Pharmaceuticals				
Acetaminophen	350,000,000 ng/L	>350,000,000	>350,000,000	>35,000,000
Ibuprofen	120,000,000 ng/L	>120,000,000	56,000,000	>280,000,000
Carbamazepine	186,900,000 ng/L	10,000,000	1,200,000	>190,000,000
Gemfibrozil	140,000,000 ng/L	8,600,000	2,300,000	>140,000,000
Sulfamethoxazole	160,000,000 ng/L	>80,000,000	720,000	>160,000,000
Meprobamate	280,000,000 ng/L	17,000,000	8,800,000	>930,000,000
Primidone	58,100,000 ng/L	10,000,000	450,000	>58,000,000
Others				
Caffeine	70,000,000 ng/L	3,500,000	>70,000,000	>23,000,000
17-β Estradiol	3,500,000 ng/L	>35,000,000	>35,000,000	>35,000,000
Triclosan	2,100,000 ng/L	>3,500,000	840,000	>2,100,000
TCEP	2,100,000 ng/L	>84,000	5,800	>210,000
PFOS	200 ng/L	17	4	>200
PFOA	400 ng/L	36	19	>80

NOTES: > indicates that the assumed concentration was below detection, and only an upper limit on the risk calculation was determined. See Appendix A for further detail. *Sources of the risk-based action limits are provided in Table A-11 of Appendix 11.

Toxicity Index vs. Current Regulatory Approach

- Mix of
 - Bulk parameter surrogates
 - TOC < 0.5 mg/L in CA
 - Limits on specific chemicals (e.g., MCLs)
 - THM4 < 80 µg/L
 - NDMA < 10 ng/L

Challenges with the Current Approach

1. Bulk parameter surrogates – TOC < 0.5 mg/L

- Does TOC reflect anthropogenic contaminants?
 - TOC likely reflects high molecular weight, non-toxic biopolymers
 - Not the low molecular weight contaminants at ng/L – µg/L
- Drives process selections (RO) with drawbacks
 - High energy/brine disposal
- Interest in alternatives (O₃/BAC)
 - But how to validate effluent chemical quality?

Challenges with the Current Approach

2. Are specific targets (THMs, NDMA) the most important?

- Choice of target drives treatment train design
 - Each disinfectant produces different carcinogens
 - Chloramines → NDMA
 - Chlorine → THMs, etc
 - Which are the toxicity drivers?

Challenges with the Current Approach

3. Regulations target different risk levels

- NDMA at 10^{-5} lifetime cancer risk (10 ng/L)
- Bromate at 10^{-4} lifetime cancer risk (10 $\mu\text{g/L}$)
- Does this bias treatment towards NDMA control?

Challenges with the Current Approach

4. Focus on individual chemicals

- No explicit consideration of mixtures
- Water with 10 contaminants each just below MCLs “safer” than water with 1 contaminant at MCL

Challenges with the Current Approach

5. No solid basis for comparison

- 1000s of chemicals in wastewater
 - Each detection in reuse water → “the sky is falling”
 - Do they really matter?
- Contaminants occur in conventional drinking waters too (DBPs)
- When are reuse waters “safe enough”?


Proposed Approach

- **Contribution to toxicity = Concentration x Toxic Potency**
 - **Weight measured concentrations by toxic potency**
 - On a common risk basis (50%):
 - 50% risk for cytotoxicity (LC₅₀) in CHO cells
 - Broad toxicity metric
 - Quantitative data is available
 - [DBP]/LC₅₀
 - **Sum toxicity-weighted contaminant concentrations**
 - Assumes risk is additive
 - **Compare these values between reuse and conventional drinking water**
 - Considered safe by regulators and the public


Proposed Framework

- ❑ Comparing potable reuse to local conventional DW
- ❑ Compare toxicity-weighted stacked bars
 - ❑ If potable reuse stacked bar \leq conventional \rightarrow “safe”
 - ❑ If potable reuse $>$ conventional \rightarrow improve treatment until lower
 - Choose a treatment that targets the “toxicity driver”

Current



Proposed



Example 1: Chlorine

❑ Non-RO-based advanced train vs. conventional DW


- ❑ Advanced train: **Secondary** → UF → **O₃/BAC** → **O₃** → BAC → **chlorinate**
- ❑ Conventional DW: Sample upstream of disinfection → **chlorinate**
- ❑ Chlorination: 1 mg/L residual after 24 h at pH 8 (Uniform Formation Conditions (UFC))
- ❑ 4 sample events over a year

❑ DOC

- ❑ Conventional: 0.86-1.46 mg/L
- ❑ Potable reuse: 1.17-2.60 mg/L

❑ Regulated DBPs (existing regs unlikely to disappear)


- ❑ Both meet limits



Example 1: Chlorine


☐ Chlorinated potable reuse (PR) higher than chlorinated DW

- ☐ Mass basis: THMs/HAAs important (not nitrosamines)
- ☐ Toxicity-weighted: halogenated aldehydes, haloacetonitriles dominate
 - THMs/HAAs/nitrosamines not so important



Example 1: Chlorine

- Chlorinated potable reuse (PR) higher than chlorinated DW
 - Mass basis: THMs/HAAs important (not nitrosamines)
 - Toxicity-weighted: halogenated aldehydes, haloacetonitriles dominate
 - THMs/HAAs/nitrosamines not so important




Example 2: Chloramines

□ Non-RO-based advanced train vs. conventional DW

- Advanced train: **Secondary** → Softening → UV/AOP → **BAC** → **GAC** → **chloramines**
- Conventional DW: Sample upstream of disinfection → **chloramines**
- Chlorination: 5 mg/L residual for 3 days at pH 8 (Uniform Formation Conditions (UFC))
- 4 sample events over a year

□ Reuse lower than DW

- Mass basis: THM4, HAA9
- Toxicity basis: HANs and HALs




Overall Chlorine vs. Chloramines

- 5 non-RO reuse facilities: DW vs. Potable reuse effluents

- Sorted by chlorine or chloramines

- Chlorinated potable reuse effluents often higher


- Chloraminated potable reuse effluent often comparable



O₃/BAC/GAC vs. MF/RO/AOP

Parallel pilot trains

- Chlorine UFC-treated effluents
- MF/RO/AOP delivers a high quality water
- GAC can help reduce calculated toxicity after O₃/BAC




Overall

- Potable reuse can deliver comparable or higher DBP-associated water quality to conventional drinking water
 - MF/RO/AOP higher quality even with chlorine
 - O_3 /BAC/GAC \approx conventional drinking water if use chloramines

Benefits

- Considers toxins
 - Not bulk parameters of unclear meaning
- Evaluates on a common risk basis
 - MCLs don't \rightarrow unfairly weight certain chemicals (NDMA over bromate)
- Considers mixtures \rightarrow estimate whole exposure
- Helps to prioritize potential toxicity drivers
 - Flexibility to utilities
 - Goal is to reduce overall toxic exposure, not individual MCLs
- Comparison to current tap water as accepted level of safety
 - Otherwise a moving goalpost – every detection a problem



CECs

Quarterly Monitoring


Regulated and
UCMR Relevant
Chemicals

DBPs


**CEC
Surrogates**

Bioassays*


- Good removal of CECs in DPR trains is important to ensure removal of unknown hazardous compounds or known compounds where human health risk data is lacking (e.g, PFAS)




Group I:
Sulfamethoxazole




Group II:
Diphenhydramine



Group III:
Primidone




Group IV:
Iohexol





Park, M., Anumol, T., Daniels, K.D., Wu, S., Ziska, A.D., Snyder, S.A., 2017. *Water Res.* 119, 21-32

CEC Occurrence





CEC Removal



Average DW Source Removal = 42%


Average Potable Reuse Removal = 89%

CEC Breakdown



HC: Household chemical; I/CC: Industrial/commercial chemical; PCP: Personal-care product; Pest.: Pesticide; PFC: Perfluorinated compound; Pharm.: Pharmaceutical; S/H: Steroid/Hormone

CEC Performance Indicators






- Framework proposes that select CECs be used as treatment performance indicators to ensure proper operation of AWT for removal of chemicals with similar properties
- Selection of CEC performance indicators:
 - Prevalent in secondary effluent at significant concentrations
 - Physical/chemical properties prove good removal of AWT treatment processes
- Proposed Limit: > 75% removal across treatment train


CEC Performance Indicators

CEC	Prevalence In Secondary Effluent Samples	Concentration (ng/L)	AWT Processes Verified
Sulfamethoxazole	100% present	Range: 44 – 3,671 50 th perc = 577	Oxidation
Iohexol	80% present	Range: BDL – 32,000 50 th perc = 2,357	Oxidation, Biofiltration, Adsorption
Sucralose	95% present	Range: BDL – 110,000 50 th perc = 20,590	Adsorption


GAC Regeneration Required



Bioassays




- Used to identify the overall toxicity of known and unknown contaminants in a mixture with the use of a biological system
- Samples concentrated 12.5x
- 5 *in vitro* bioassays tested:
 - Estrogen Receptor (ER)
 - Glucocorticoid Receptor (GR)
 - Aryl hydrocarbon Receptor (AhR)
 - p53 pathway
 - HepG2 (Cytotoxicity)





Escher, B. I., et al. (2014). *Environ. Sci. Technol.* 48(3), 1940–1956

Observed Bioactivity in WWTPs Sec. Effluent




Bioassay Results (AhR and ER)

- About 20 samples analyzed for each type of water across the six utilities
- Proposed Limit for Framework:
 - $BEQ/MTL < 10$
 - BEQ = bioanalytical equivalent concentration
 - MTL = monitoring trigger level
- More work required on bioassays:
 - Development of standard measurement methods
 - Interpretation of results




Jia, A., Wu, S., Daniels, K.D., Snyder, S.A., 2016. *Environ. Sci. Technol.* 50, 2870–2880.

Testing the Framework



Testing the Framework – Utility D




Testing the Framework - TOC

Parameter	Event 1	Event 2	Event 3	Event 4
TOC				
DBP Toxicity Index				
CEC Surrogates				
Bioassays				


Testing the Framework - TOC

Parameter	Event 1	Event 2	Event 3	Event 4
TOC	> Alert Limit	> Alert Limit	< Alert Limit	< Alert Limit
DBP Toxicity Index				
CEC Surrogates				
Bioassays				



Testing the Framework - TOC

Parameter	Event 1	Event 2	Event 3	Event 4
TOC	> Alert Limit	> Alert Limit	< Alert Limit	< Alert Limit
DBP Toxicity Index	< DW TI _{annavg}	< DW TI _{sample}	< DW TI _{annavg}	< DW TI _{annavg}
CEC Surrogates				
Bioassays				




Testing the Framework - TOC

Parameter	Event 1	Event 2	Event 3	Event 4
TOC	> Alert Limit	> Alert Limit	< Alert Limit	< Alert Limit
DBP Toxicity Index	< DW TI _{annavg}	< DW TI _{sample}	< DW TI _{annavg}	< DW TI _{annavg}
CEC Surrogates	>75% removal	>75% removal	>75% removal	>75% removal
Bioassays				

Sample Event	Sulfamethoxazole	Iohexol	Sucralose
1	>97%	>98%	93%
2	>96%	>98%	75.2%
3	>99%	>96%	>96%
4	>96%	>91%	89%

Testing the Framework - TOC

Parameter	Event 1	Event 2	Event 3	Event 4
TOC	> Alert Limit	> Alert Limit	< Alert Limit	< Alert Limit
DBP Toxicity Index	< DW TI _{annavg}	< DW TI _{sample}	< DW TI _{annavg}	< DW TI _{annavg}
CEC Surrogates	>75% removal	>75% removal	>75% removal	>75% removal
Bioassays	BEQ/MTL < 10	BEQ/MTL < 10	BEQ/MTL < 10	BEQ/MTL < 10



✓ -Pass

Conclusions

- Domestic water cycle adds significant refractory organics
- TOC provides some correlation to potential health relevance (e.g., chemicals, DBPs) – include in framework as an indicator
 - Absolute value that is universally applied across geographies is not appropriate nor necessarily protective of public health – set local TOC limit based on drinking water TOC
- Measurement of TOC, DBPs, CECs, and bioassays provide good assurance that water is of similar quality to local drinking water
- A GAC adsorption process (with periodic regeneration) is critical for non-RO based treatment in DPR applications
 - Oxidation and biological filtration alone likely not sufficient



THE
**Water
Research**
FOUNDATION

Questions?



JACOBS®





THE
**Water
Research**
FOUNDATION

Thank You

Comments or questions, please contact:

jmattingly@waterrf.org

For more information, visit

www.waterrf.org

