Denver Water Dynamic and Adaptive Master Plan



Kedric Szana

Water Research Foundation's Intelligent Water Networks Summit

DENVER WATER

Denver Water

Colorado's oldest and largest water utility.



Denver Water System



- Supply by 3 treatment plants
- 3,100 miles of pipelines
- 33,000 Hydrants
- 144 pressure zones
- 150 major control valves
- 520 PRVs
- 58 storage tanks
- 200 pump units in 51 stations
- Over 50 distributors

Innovation, strategic planning, advanced technologies are a chosen path for Denver Water

Denver Water Drivers and Motivation

- Population growth
- Climate change
- Periodic drought
- Competition for water resources
- Changing water usage
- Changing regulatory and political environment.
- Maximize water efficiency



Dynamic Adaptive Master Plan Using an Optimization Approach Why?



Optimization

Provides unbiased and transparent cost-effective solutions.





Treated Water Planning Study and Integrated Resource Plan In Progress

Guide decisions over the next 50 years.





Recently updated Innovyze InfoWater Hydraulic Model

Evaluates the hydraulic performance of various alternatives.



Software: Optimizer WDS

File Home	View Project									۵
Copy Paste New	Delete Add Remove	Evaluate Input Model	Zoom	Extents	Activate Evaluate	Start Stop Stop	Start Stop	Model Form	aulate Plan Optimi	ze
Clipboard	Data	Solver	Map Zoom & Selection	Map Views	Plan	Optimization	Replay		Workflow	
Project Ex 4 ×	Map Display X	Metrics 🗙 🥕 Pare 🗙						• ×	Plan Editor	μ×
 Pipe Pump Curve Tank Valve Time Control Trigger Contro Adjusters Capital Operating Design Criteria Pressure Velocity Flow Group Flow Unit Head Loss Tank Storage Pressure Differ Pump Operatic Optimization Options Objectives Map Display 									 PC: Pressure (\$) PC: TankLevels (\$) PC: Pressure Difference PC: PRVOPCost (\$) PC: FFPressure (\$) OC: CLVA_32089 DCS-CLVA_2414	ence (\$) > Valve > Valve -> (-) (-) (-) (-) (-) (-) (-) (-) (-) (-)

E	Data Browser - Valve Decision	ns							4	×	
		Settings	General	General		Valve Options					
	ID 🔺	Settings	Active	Planning Criteria	Group Decision	Can Open Valves	Can Close Valves	Remove Close	Set HGL		
	DCS-CLVA_3685	0,59,61,63,65,67,69,71		PRVOpCost						*	
	DCS-CLVA_3725	0,72,74,76,78,80,82,84		PRVOpCost							
	DCS-CLVA_3738	0,87,89,91,93,95,97,99		PRVOpCost							
		▲							-		
Data Browser - Valve Decisions											



A Step by Step Journey



Dynamic Adaptive Master Plan





Optimization Software Data Needs





Pump off/on level controls Control valve settings and

 Control valve settings and status



Improvement options

Cost information

- InfoWater model
- Hydraulic model skeletonized to 60,000 pipes, original model had 350,000
- Extended period simulation (24hr) of 2016 Maximum Day Conditions.



Optimization Goals

Which set of operating conditions will have the least energy cost while meeting service level goals for pressure, tank turnover, and tank recovery.



Optimization Decisions



Pump Unit

- On and Off control levels
- Status (open/close)



Control Valves

Supply flow

- On and Off control levels
- Setting
- Status (open or close)

WTP
• Sup

	g Da	Data Browser - Trigger Control Decisions							
			General		Settings				
	R	ID 🔺	Active	Planning Criteria	Settings (ft)				
Þ	1	BELLEVIEW_HIGH_SIDE_P4-Off	V	OperatingCost	16,18,19,20,21				
	1	BELLEVIEW_HIGH_SIDE_P4-On	\checkmark	OperatingCost	12,14,16,19				
	1	BELLEVIEW_HIGH_SIDE_P5-Off	\checkmark	OperatingCost	16,18,19,20,21				
	1	BELLEVIEW_HIGH_SIDE_P5-On	\checkmark	OperatingCost	12,14,16,19				
	1	BELLEVIEW_HIGH_SIDE_P6-Off	\checkmark	OperatingCost	16,18,19,20,21				
	1	BELLEVIEW_HIGH_SIDE_P6-On	\checkmark	OperatingCost	12,14,16,19				
	1	BELLEVIEW_HIGH_SIDE_P7-Off	\checkmark	OperatingCost	16,18,19,20,21				
	1	BELLEVIEW_HIGH_SIDE_P7-On	\checkmark	OperatingCost	12,14,16,19				
	1	BELLEVIEW_LOW_SIDE_P1-Off	\checkmark	OperatingCost	17,19,20,21				
	1	BELLEVIEW_LOW_SIDE_P1-On	\checkmark	OperatingCost	10,12,14,16				
	1	BELLEVIEW_LOW_SIDE_P2-Off	\checkmark	OperatingCost	17,19,20,21				
	1	BELLEVIEW_LOW_SIDE_P2-On	\checkmark	OperatingCost	10,12,14,16				
	1	CHATFIELD_HS_P5-Off	\checkmark	OperatingCost	17,19,20,21,22				
	1	CHATFIELD_HS_P5-On	\checkmark	OperatingCost	12,14,16,18				
	1	CHATFIELD_HS_P6-Off	\checkmark	OperatingCost	17,19,20,21,22				
	1	CHATFIELD_HS_P6-On	\checkmark	OperatingCost	12,14,16,18				
	1	CHATFIELD_HS_P7-Off	\checkmark	OperatingCost	17,19,20,21,22				
	1	CHATFIELD_HS_P7-On	\checkmark	OperatingCost	12,14,16,18				
	1	CHERRY HILLS P1-Off	\checkmark	OperatingCost	15.17.18.19				

144 Trigger Control Decisions

The Optimization software evaluates **the potential combinations** of the decisions for each pump unit, control valve and treatment plant.

Pareto Optimal Front – Multi-Objective

Inflection points- good alternatives with different operating cost and different levels of hydraulic performance



Operating Cost (\$)

Optimization Results



Plar	Editor							
		InputModel	Plan001	Plan002	Plan003	Plan004	Best SO	
PC:	Pressure (\$)	31,958.63	43,394.53	43,494.21	2,528.09	2,765.39	2,045.00	
PC:	OperatingCost (\$)	10,727.41	6,238.37	6,233.43	5,681.74	7,404.33	7,388.14	
PC:	TankLevels (\$)	686,201.64	2,101,696.14	1,079,834.13	544,015.11	442,255.63	104.29	
C:	TreatmentCost (\$)	45,509.93	31,039.92	34,434.92	39,769.92	41,709.92	47,044.92	
PC	PumpRun (\$)	1,483.75	487.50	134.75	34.50	244.25	58.50	
PC:	PressureDifference (\$)	0.00	0.00	0.00	0.00	0.00	0.00	
0:0	D1-Cost (\$)	56,237.34	37,278.29	40,668.36	45,451.66	49,114.26	54,433.06	
0:0	02-Performance (\$)	719,644.02	2,145,578.17	1,123,463.09	546,577.71	445,265.27	2,207.79	
МА	RSTONFLOW -> Valve MARSTON_FCV	Setting: 50000	Setting: 30000	Setting: 35000	Setting: 30000	Setting: 35000	Setting: 45000	
KEI	NDRICK_HS_P11-Off -> Control	17ft	21ft	21ft	21ft	21ft	21ft	
KEI	NDRICK_HS_P11-On -> Control	10ft	10ft	10ft	10ft	10ft	14ft	
VD.	CONTROLVALVES -> Valve CNVA_3127	Setting: 100	Setting: 5	Setting: 1e+006	Setting: 5	Setting: 5	Setting: 100	
VD.	CONTROLVALVES -> Valve CLVA_1269	Setting: 1e+006	Setting: 250	Setting: 250	Setting: 250	Setting: 250	Setting: 1000	
VD.	CONTROLVALVES -> Valve CLVA_1186	Setting: 1e+006						
VD.	CONTROLVALVES -> Valve	Setting: 1e+006	Setting: 1000					
FO	OTHILLSFLOW -> Valve FOOTHILLS_FCV	Setting: 155000	Setting: 140000	Setting: 155000	Setting: 155000	Setting: 155000	Setting: 155000	
VD.	_CLVA_361 -> Valve CLVA_361	Setting: 50	Setting: 10	Setting: 1000	Setting: 1e+006	Setting: 1e+006	Setting: 250	
LOI	NE_TREE_HS_P7-Off -> Control	19ft	21ft	22ft	22ft	22ft	20ft	
LOI	NE_TREE_HS_P7-On -> Control	14ft	12ft	12ft	12ft	12ft	12ft	
LOI	NE_TREE_HS_P6-Off -> Control	20ft	17ft	17ft	17ft	22ft	17ft	
LOI	NE_TREE_HS_P6-On -> Control	14ft	16ft	16ft	16ft	12ft	16ft	
LOI	NE_TREE_LS_P5-Off -> Control SC0000FF	67psi	67psi	69psi	68psi	69psi	68psi	
LOI	NE_TREE_LS_P5-On -> Control	63psi	63psi	63psi	66psi	66psi	66psi	
LOI	NE_TREE_LS_P4-Off -> Control	67psi	68psi	70psi	68psi	67psi	69psi	
LOI	NE_TREE_LS_P4-On -> Control	63psi	63psi	64psi	63psi	63psi	64psi	
LOI	NE_TREE_HS_P8-On -> Control	18ft	14ft	12ft	18ft	18ft	14ft	
LOI	NE_TREE_HS_P8-Off -> Control	17ft	22ft	19ft	22ft	22ft	20ft	



Project Outcomes

- Storage analysis matched views of O&M
- Interesting operations on max day
- Ideas for future analysis and optimization



Hidden Issues – Water Optimization is More Complex than Sewer or Flooding

- Sewer / River / Combined Optimization
 - Cost
 - Minimize Flooding
- Water Optimization
 - Source Availability
 - Conduit Outages
 - WTP Outages
 - Fireflow
 - One Side Out Analysis
 - Demand Variations



Future Potential Optimization Projects at Denver Water



Downtown Area Pipe Replacement Project



Continue Optimization of Operation Alternatives -200-300 MGD and Raw Water



Shoulder Month Operations



Major Improvements of





Source Water Management **Optimization**

Real-Time Modeling



Optimization for Risk Reduction and Resilience Enhancement

Plant Outage Planning

Future Goals

- Optimize Optimization
- Real-Time Modeling
- Raw Water Side
- CIP Optimization
- Finalize GIS Integration



Partnerships



Innovyze[®] Optimatics





Thank You!

